

**STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC POOL AND BATHING PLACE
INSPECTION REPORT**



1 of 2

Facility Information

RESULT: Pool Closed

Permit Number: 06-60-00566
Name of Facility: Citation Way Condominium (Spa)
Address: 9845 Westview Drive
City, Zip: Coral Springs 33076

**Correct By: by 8:00 AM
Re-Inspection Date: 3/8/2024**

Type: Spa-Type Pools
Owner: Citation Way Condominium Association, Inc.
Person In Charge: Integrity Property Management, Phone: (954) 575-1111
PIC Email: LINDA@IPMFLORIDA.COM
Pool Operator: BLUE DIAMOND POOLS Phone: 561-674-8549

Inspection Information

Purpose: Reinspection
Inspection Date: 2/15/2024
Begin Time: 10:01 AM
End Time: 10:12 AM

Additional Information

22. Free Chlorine 3	VOLUME 900
23. pH 7.8	POOL LOAD 6
24. Chlor. Stabilizer 0	FLOW RATE 50
33. Flowmeter 50	NIGHT SWIM No
34. Thermometer 101	FILTER TYPE CP

Items checked are not in compliance with Chapter 386 or 514, Florida Statutes, or Chapter 64E-9 or 64E-10, Florida Administrative Code. These violations must be corrected by the date indicated to avoid closure, administrative fines, or other legal actions. Florida Building Code (FBC) violations are reported to the local building official, and depending upon risk severity, the Department of Health may close the pool or rescind the operating permit.

Violation Markings

POOL AREA 1. Water Clarity/Algae Control 2. Deck/Walkways 3. Tile/Pool Finish 4. Depth Markers-FBC 5. Handrail/Ladder-FBC 6. Step Markings-FBC 7. Suction Outlets-514.0315(1) 8. Gutter Grates/Skimmer-FBC 9. Lighting 10. No Dive Markings-FBC 11. Diving Board-FBC 12. Pool Cover 13. Pool Side Shower-FBC POOL SAFETY 14. Life Hook(s) w/Pole X 15. Life Ring(s) w/Rope 16. Safety Line	17. Rules Posted 18. Certification SANITARY FACILITIES 19. Supplies 64E-10, FAC 20. Clean 64E-10, FAC WATER QUALITY 21. Approved Test Kit 22. Free Chlor./Brom. 23. pH 24. Chlor. Stabilizer 25. Spa Requirements-ORP EQUIPMENT ROOM 26. Wading Pool-Quick Dump 27. Water Level/Control 28. Disinfection Feeder/Generator 29. pH Feeder 30. Chem. Container Label-FBC 31. Filter / Pump	32. Vacuum Cleaner-FBC 33. Flowmeter 34. Thermometer 35. Pressure/Vacuum Gauge 36. Equip. Room 37. Cross Connection 38. Gas Chlorine Eq.-FBC 39. Waste Water - FBC 40. D.E. Separator-FBC 41. Other Equipment 42. Equip. Change-FBC 43. Approved Chemicals X 44. Maintenance Log 45. Inspection Posted 46. Safety-514.0315(2) 47. Fences/Gates- FBC 48. Other 49. Other
---	--	--

NOTE: It is unlawful to modify a public pool or its equipment without prior approval from the local building department and submitting an application to DOH.

Inspector Signature:

Client Signature:

EMAIL

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC POOL AND BATHING PLACE
INSPECTION REPORT



2 of 2

General Comments

SPA CLOSED

ENOV STILL IN EFFECT

Email Address(es): INVOICES@IPMFLORIDA.COM;
LINDA@IPMFLORIDA.COM;
INFO@BBUEDIAMONDPOOLS.COM

DOH Web Page For Pools: <http://www.floridahealth.gov/environmental-health/swimming-pools/index.html>

Violations Comments

Violation #15. Life Ring(s) w/Rope

OBSERVED LIFE RING WITH SUFFICIENT ROPE ATTACHED IS DECORATIVE ONLY AND IS NOT APPROVED FOR LIFE SAVING - POOL CLOSED. PROVIDE FBC APPROVED LIFE RING (16-24 INCH DIAMETER LIFESAVING RING WITH SUFFICIENT ROPE ATTACHED, APPROVED OR CERTIFIED UNDER A NATIONALLY RECOGNIZED WATER SAFETY DEVICE STANDARD. REFER TO FBC 454.1.3.3.1 FOR REQUIREMENTS CODE REFERENCE: Life Ring with Rope. 64E-9.008(3). An 18 inch diameter lifesaving ring with sufficient rope attached to reach all parts of the pool must be provided. The rope must be in good condition. The ring must be fully accessible, visible and not tied down or locked. Pools over 50 feet in length must have a lifesaving ring along each of the longer sides of the pool.

Violation #44. Maintenance Log

OBSERVED POOL MAINTENANCE LOG FOR OCTOBER 2023 IS MISSING. PROVIDE POOL MAINTENANCE LOG.

CODE REFERENCE: Maintenance Log. 64E-9.004(10). Daily record must be kept for pH and disinfectant residual tested each day the pool is open for use, and weekly for Cyanuric Acid.

Inspection Conducted By: Louis Fisher (68963)
Inspector Contact Number: Work: (954) 412-7329 ex.
Print Client Name:
Date: 2/15/2024

Inspector Signature:

Handwritten signature of Louis Fisher.

Client Signature:

Handwritten signature "EMAIL".